



Energy Recovery Filter Specification

Provide Accurex Energy Recovery Filters as shown on plans and in accordance with the following specification:

Note to User: This document is subject to copyright protection and is proprietary to Accurex Engineered Restaurant Systems. However, Accurex Engineered Restaurant Systems authorizes the user a limited non-exclusive license to use this document or portions of it for the purpose of preparing written product specifications. All information in this document as provided by Accurex Engineered Restaurant Systems is informational in nature and is provided without representation or warranty of any kind as to the user or any other party, including, without limitation, ANY IMPLIED WARRANTY OF MERCHANTABILITY, FITNESS FOR PARTICULAR PURPOSE, OR NON-INFRINGEMENT. To the greatest extent permitted by applicable law, Accurex Engineered Restaurant Systems assumes no liability, and User assumes all liability and risk, for the use or results from the use of this document or the information contained herein, whether as modified by the user or not. Users should consult www.accurex.com to verify that this document represents the most current version.

The Energy Recovery high efficiency stainless steel filters shall be U.L. 1046 Classified and NSF Certified as manufactured by Accurex, in sufficient number and sizes to ensure optimum performance. Energy Recovery Filters shall direct the exhaust airflow across integral copper heat exchangers with industrial grade quick disconnects, utilizing liquid cooled grease extraction technology. The filter housing shall terminate in a pitched, full length grease trough which shall drain into a removable grease container. These filters shall have a grease removal efficiency of 88% at 8 microns (60% from 3-10 microns) and static pressure drop of 0.6-0.7 inWC.

Due to continuous research Accurex reserves the right to change specifications without notice.