



## Switches Only

\*\*\*\*\*  
**Note to User:** This document is subject to copyright protection and is proprietary to Accurex Engineered Restaurant Systems. However, Accurex Engineered Restaurant Systems authorizes the user a limited non-exclusive license to use this document or portions of it for the purpose of preparing written product specifications. All information in this document as provided by Accurex Engineered Restaurant Systems is informational in nature and is provided without representation or warranty of any kind as to the user or any other party, including, without limitation, ANY IMPLIED WARRANTY OF MERCHANTABILITY, FITNESS FOR PARTICULAR PURPOSE, OR NON-INFRINGEMENT. To the greatest extent permitted by applicable law, Accurex Engineered Restaurant Systems assumes no liability, and User assumes all liability and risk, for the use or results from the use of this document or the information contained herein, whether as modified by the user or not. Users should consult [www.accurex.com](http://www.accurex.com) to verify that this document represents the most current version.  
\*\*\*\*\*

Provide Switches as shown on plans and in accordance with the following specification:

Switches only shall be provided on a switch plate mounted to the face of the hood, shipped loose for installation by others, attached to utility cabinet or utility distribution system. The switches shall be to control the lights, fans or call for heating or cooling (tempering) from the MUA unit. All wiring will be by others for the switches only selection.

Due to continuous research Accurex reserves the right to change specifications without notice.